

Prepared For:  
Client Name

**Limited ADA Compliance Schedule**



Summary of area: **Building Name**  
123 Main Street  
(Suite xxxx)  
Anytown, USA

**Restroom One**

| Accessible Element   | Requirement  | Complies Yes/No | Comment:                    |
|----------------------|--|-----------------|-----------------------------|
| Entry door           | Clear floor space-pull side (at least 30" x 48")                         | Yes             |                             |
|                      | Clear floor space-push side  | Yes             |                             |
|                      | Door width (at least 32" wide)   | Yes             |                             |
|                      | Accessible hardware (all no higher than 48" from floor)                  | Yes             |                             |
| Lavatory             | Clear floor space at least 30" x 48" deep, no more than 19" under        | Yes             |                             |
|                      | Rim height (at least 29" clearance from bottom apron)                    | Yes             |                             |
|                      | Knee space   | Yes             |                             |
|                      | Protection from sharp/hot objects  | Yes             |                             |
|                      | Accessible hardware  | Yes             |                             |
| Lavatory accessories | Mirror (bottom no higher than 40" from floor)                            | No              | Mirror > 40" from floor     |
|                      | Soap dispenser (no higher than 44")                                      | N/A             | Soap dispenser not observed |
|                      | Paper towel dispenser (15" to 48" above floor)                           | Yes             |                             |
| Toilet               | Clear floor space  | Yes             |                             |
|                      | Toilet centerline dimension (at least 18" from side walls)               | Yes             |                             |
|                      | Seat height (17" to 19")   | Yes             |                             |
|                      | Side grab bar(s) length (at least 42" and max. 12" from back wall)       | Yes             |                             |
|                      | Side grab bar(s) height (33" to 36" tall)                                | Yes             |                             |
|                      | Rear grab bar length (at least 36" and min 12" from centerline)          | Yes             |                             |
|                      | Rear grab bar height (33" to 36" tall)                                   | Yes             |                             |
| Toilet accessories   | Toilet paper holder (located 7-9" in front of toilet and 15-48" from FL) | No              | Nearest dispenser damaged   |
|                      | Seat cover dispenser   | N/A             | Dispenser not observed      |
| Toilet stall         | Door width   | Yes             |                             |
|                      | Door hardware  | Yes             |                             |
|                      | Self closing   | No              | Not a self closing door     |
| Urinal               | Clear floor space (30" wide x 48" deep approach)                         | N/A             | Urinal not observed         |
|                      | Rim Height (no higher than 17" above floor)                              | N/A             | Urinal not observed         |